



NYSEG Elevated Pressure Commitment Letter

Customer Name _____

Address _____

City _____ State _____ ZIP _____

Requested Service Pressure _____ Estimated Demand (MCFH) _____

Service pressures in excess of 7" water column require special precautions and construction practices. Your entire gas piping system, including pressure reduction regulators, must be installed according to the requirements of the Fuel Gas Code of New York State, New York State regulations and other local regulations as these requirements or regulations may be amended, modified or superseded. There may also be requirements imposed by your fire insurance carrier and local building inspector. If you have any questions, please call **1.800.572.1111**, Monday through Friday, 7 a.m. to 4:30 p.m. Using the automated system, press 3 for "Start or Stop Service, New Construction or Upgrades" and then press 3 again for "New Construction or Upgrading Service."

PLEASE READ THIS SECTION CAREFULLY AND COMPLETELY

I agree in signing below to the following:

- I will install or cause to install all of my piping and related equipment in accordance with the most current editions of the Fuel Gas Code of New York State, New York State regulations and other local regulations and manufacturer's instructions.
- I will install a pressure reducing device on any appliance that is designed to operate at a pressure less than the delivery pressure.
- I will install a vent piping system leading to the outdoors for all pressure relief devices, and any pressure regulators without a properly installed vent limiting device.
- I will notify the Company before making any changes/additions to my piping system or appliances.
- I will perform an annual inspection of my pressure regulators and relief devices. Qualified individuals should perform these inspections.
- The Company has no responsibility for my gas appliances and related gas equipment such as regulators and relief devices that I, my contractor or builder have installed or will in the future install and I agree to take full and complete responsibility for my gas appliances and related gas equipment such as regulators and relief devices.
- I will reimburse the Company \$350.00 plus tax for the increased cost in providing this elevated delivery pressure.

It is further agreed, for delivery pressures greater than 2 psig:

- I will install devices for the sole purpose of automatically taking over in an emergency to control the downstream pressure in the event of a regulator failure. This can be done by using internal relief regulators, a monitor regulator system, a separate pressure relief valve or a high-pressure shut-off switch and valve.

Authorized Representative (Please Print) _____ Date _____

Signature _____ Title _____

Please email an electronic copy of the signed application to NYSEGESI@nyseg.com or fax to 844.515.1573 or mail to NYSEG, Attn: Energy Service Installation, Customer Relations Center, P.O. Box 5240, Binghamton, NY 13902-5240.