

NYSEG QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Afton	Substation Transformer	\$4,214,044	17.25	11%	3-5 years
Apalachin Tap	3V0 Installation	\$455,244	22.50	25%	18 months
Arkville	3V0 Installation	\$658,051	6.60	0%	
Atlanta	Substation Transformer	\$376,410	18.30	27%	3-5 years
Auburn	3V0 Installation	\$661,915	5.17	0%	
Auburn	Distribution Line Upgrade	\$1,972,607	9.80	0%	
Axtell Rd	3V0 Installation	\$721,933	27.22	37%	18 months
Banker Road	3V0 Installation	\$672,191	6.75	45%	18 months
Banker Road	Distribution Line Upgrade	\$997,226	9.80	0%	
Banker Road	Substation Transformer	\$4,056,999	16.80	0%	
Bankert Rd	3V0 Installation	\$631,533	10.30	0%	
Bankert Rd	Distribution Line Upgrade	\$621,000	4.28	0%	
Bankert Rd	Substation Transformer	\$3,864,106	6.38	0%	
Bennett	Distribution Line Upgrade	\$621,000	9.80	0%	
Bennett	Distribution Line Upgrade	\$310,500	0.78	0%	
Bennett	Substation Transformer	\$4,218,432	10.50	0%	
Bennington	3V0 Installation	\$692,192	2.06	0%	
Brooktondale Tap	Distribution Line Upgrade	\$993,600	25.89	0%	
Brothertown	3V0 Installation	\$676,057	2.90	0%	
Burdett	3V0 Installation	\$370,515	1.60	0%	
Cabot Mine	3V0 Installation	\$698,039	7.57	0%	
Cabot Mine	Distribution Line Upgrade	\$2,205,868	3.88	0%	
Campbell	3V0 Installation	\$603,749	21.67	0%	
Campbell	Distribution Line Upgrade	\$3,793,037	9.80	0%	
Campbell	Substation Transformer	\$4,307,227	21.67	0%	
Cemetery Rd	3V0 Installation	\$594,698	7.56	30%	18 months
Chemung	3V0 Installation	\$723,308	11.97	0%	
Chemung	Distribution Line Upgrade	\$627,210	9.80	0%	
Chemung	Substation Transformer	\$4,241,981	11.97	0%	
Chestnut Ridge	3V0 Installation	\$448,646	10.50	48%	18 months
Chestnut Ridge	Distribution Line Upgrade	\$496,800	10.50	100%	18 months
Columbus	3V0 Installation	\$468,239	16.80	30%	18 months
Conklin	3V0 Installation	\$631,308	3.65	0%	
Dannemora	3V0 Installation	\$702,474	5.70	0%	
Dannemora	Substation Transformer	\$3,625,220	5.70	0%	
Dover Plains	3V0 Installation	\$514,074	6.30	56%	18 months
Dundee	3V0 Installation	\$660,480	4.14	0%	
Dundee	Distribution Line Upgrade	\$683,100	9.80	0%	
Earlville	3V0 Installation	\$651,184	10.50	0%	
Earlville	Distribution Line Upgrade	\$4,220,563	9.80	0%	
Earlville	Substation Transformer	\$4,036,938	10.50	0%	
Emmons	3V0 Installation	\$661,558	3.64	27%	18 months
Fallbrook	Distribution Line Upgrade	\$956,340	9.80	0%	
Fallbrook	Distribution Line Upgrade	\$704,800	9.80	0%	
Flat St	Distribution Line Upgrade	\$6,955,200	8.74	0%	
Fosterdale	Substation Modification	\$434,244	1.45	0%	
Frog Valley	3V0 Installation	\$966,485	24.30	0%	
Frog Valley	Distribution Line Upgrade	\$3,766,093	9.80	0%	
Frog Valley	Substation Transformer	\$5,004,582	27.75	0%	
Fuller Hollow	3V0 Installation	\$436,141	16.80	0%	
Gainesville	Distribution Line Upgrade	\$1,111,838	27.11	0%	
Gates Ave	Substation Transformer	\$4,077,692	16.80	0%	
Grand Gorge	3V0 Installation	\$676,056	8.30	0%	
Grand Gorge	Distribution Line Upgrade	\$1,869,277	9.80	0%	
Grand Gorge	Substation Transformer	\$4,544,127	6.30	0%	
Hammond Lane	3V0 Installation	\$698,039	11.65	30%	18 months
Hickling	Substation Regulator	\$544,626	3.76	0%	
Howard	3V0 Installation	\$660,480	1.65	0%	
Hyatt Rd	Distribution Line Upgrade	\$9,645,903	27.11	0%	
Interlaken	3V0 Installation	\$709,309	16.80	0%	
Interlaken	Substation Transformer	\$4,659,006	16.80	0%	
Jordan Rd	3V0 Installation	\$660,480	4.20	0%	
Jordan Rd	Distribution Line Upgrade	\$310,500	9.80	0%	
Kanona	3V0 Installation	\$642,905	5.80	0%	
Kanona	Distribution Line Upgrade	\$3,235,367	9.80	0%	
Kattelville	3V0 Installation	\$676,056	21.83	26%	18 months
Kattelville	Distribution Line Upgrade	\$3,343,692	9.80	0%	
Kattelville	Distribution Line Upgrade	\$979,965	9.80	0%	
Keeseville	Distribution Line Upgrade	\$254,280	2.12	0%	
Lakeshore	3V0 Installation	\$1,101,910	3.20	0%	
Lakeshore	Distribution Line Upgrade	\$1,577,203	3.20	0%	
Langdon	Distribution Line Upgrade	\$384,009	3.68	0%	
Langdon	Substation Transformer	\$6,453,509	2.63	0%	
Legion Drive	Distribution Line Upgrade	\$1,862,032	9.80	0%	
Legion Drive	Substation Transformer	\$3,474,831	5.63	0%	
Lounsberry	3V0 Installation	\$658,079	19.35	0%	
Lounsberry	Distribution Line Upgrade	\$2,608,604	9.80	0%	
Lounsberry	Substation Transformer	\$4,995,680	19.35	0%	
Ludlowville	3V0 Installation	\$737,510	8.63	0%	
Ludlowville	Substation Transformer	\$4,652,967	8.63	0%	
Macedon	Distribution Line Upgrade	\$621,000	6.01	100%	18 months
Masons Corners	3V0 Installation	\$676,057	16.80	30%	18 months
Masons Corners	Distribution Line Upgrade	\$1,536,598	9.80	0%	
Masons Corners	Substation Transformer	\$4,425,672	5.63	0%	
Montour Falls	Distribution Line Upgrade	\$7,650,720	27.11	0%	
Montour Falls	Substation Transformer	\$6,946,715	10.50	0%	

NYSEG QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Moraine Rd	Distribution Line Upgrade	\$347,760	2.24	100%	18 months
Moravia	3V0 Installation	\$384,856	4.20	86%	18 months
Naples	Distribution Line Upgrade	\$794,880	22.35	100%	18 months
Naples	Substation Regulator	\$535,902	15.14	26%	3-5 years
Northside	Distribution Line Upgrade	\$403,650	27.10	100%	18 months
Otego	3V0 Installation	\$601,717	13.00	0%	
Otego	Distribution Line Upgrade	\$1,086,750	9.80	0%	
Otego	Source Line Regulator	\$514,112	7.50	0%	
Otego	Substation Transformer	\$4,193,376	13.00	0%	
Palmiter Rd	3V0 Installation	\$676,057	11.20	0%	
Palmiter Rd	Distribution Line Upgrade	\$1,354,190	9.80	0%	
Palmiter Rd	Substation Transformer	\$4,995,680	11.20	0%	
Perry Center	3V0 Installation	\$864,876	5.39	0%	
Perry Center	Distribution Line Upgrade	\$1,137,672	9.80	0%	
Perry Center	Substation Transformer	\$5,464,008	3.75	0%	
Peruville Tap	Distribution Line Upgrade	\$621,000	25.12	0%	
Philo Road	3V0 Installation	\$549,933	16.80	25%	18 months
Pierce Ave	Distribution Line Upgrade	\$353,098	9.24	89%	18 months
Port Byron	3V0 Installation	\$610,778	10.50	0%	
Port Byron	Substation Transformer	\$4,366,875	10.50	0%	
Presho	3V0 Installation	\$660,480	4.09	0%	
Presho	Distribution Line Upgrade	\$403,650	9.80	0%	
Randolph	3V0 Installation	\$660,480	3.60	0%	
Randolph	Distribution Line Upgrade	\$316,710	9.80	0%	
Randolph	Substation Transformer	\$3,914,215	6.75	0%	
Ridge Rd	3V0 Installation	\$657,364	3.80	0%	
Ridge Rd	Distribution Line Upgrade	\$2,527,470	9.80	0%	
Ridge Rd	Substation Transformer	\$5,109,439	21.67	0%	
Salem Tap	Distribution Line Upgrade	\$1,242,000	25.46	0%	
Seneca Falls	3V0 Installation	\$372,429	16.80	30%	18 months
Seneca Ordanance	3V0 Installation	\$467,957	3.75	96%	18 months
Silver Creek	Distribution Line Upgrade	\$738,990	TBD	100%	18 months
Sleight Rd	3V0 Installation	\$676,056	37.45	0%	
South Colden	Distribution Line Upgrade	\$622,242	4.91	0%	
South Colden	Substation Transformer	\$3,838,232	6.75	0%	
South Junction	3V0 Installation	\$444,109	10.50	75%	18 months
South Lansing Tap	Distribution Line Upgrade	\$353,340	27.10	0%	
South Park	3V0 Installation	\$584,322	16.45	23%	18 months
Springfield Center	3V0 Installation	\$665,429	6.30	0%	
Springfield Center	Distribution Line Upgrade	\$1,173,627	9.75	0%	
St Johns	3V0 Installation	\$603,748	1.47	0%	
Stanton Ave	3V0 Installation	\$701,175	7.00	43%	18 months
Stryker Ave	3V0 Installation	\$656,691	10.50	0%	
Stryker Ave	Substation Transformer	\$4,956,317	15.37	0%	
Ten Mile River	3V0 Installation	\$403,896	16.80	30%	18 months
Tilly Foster	3V0 Installation	\$438,558	27.98	25%	18 months
Tom Miller Rd	3V0 Installation	\$578,354	14.70	0%	
Van Buren St	3V0 Installation	\$391,470	10.50	85%	18 months
Van Buren St	Distribution Line Upgrade	\$7,452,000	4.54	0%	
Vestal	3V0 Installation	\$649,283	5.10	0%	
Vincent Corners	3V0 Installation	\$624,247	9.00	0%	
Vincent Corners	Substation Transformer	\$3,703,540	9.00	0%	
Walden	3V0 Installation	\$600,019	11.18	0%	
Walden	Distribution Line Upgrade	\$3,210,570	20.84	0%	
Wallace	3V0 Installation	\$471,577	6.75	0%	
Wallace	Distribution Line Upgrade	\$248,400	9.80	0%	
Wallace	Substation Transformer	\$3,469,599	6.75	0%	
Warsaw	3V0 Installation	\$327,038	4.99	0%	
Warsaw	Distribution Line Upgrade	\$3,990,958	9.80	0%	
Warsaw	Substation Transformer	\$3,080,301	2.63	0%	
Wehrle	3V0 Installation	\$572,320	5.45	0%	
Wehrle	Distribution Line Upgrade	\$2,777,980	9.80	0%	
Wende Rd	Distribution Line Upgrade	\$3,331,315	9.80	0%	
Wende Rd	Substation Transformer	\$5,239,391	17.50	0%	
West Hill	3V0 Installation	\$628,854	6.90	72%	18 months
West Winfield	3V0 Installation	\$717,201	5.67	0%	
West Winfield	Substation Transformer	\$3,434,495	5.67	0%	
Whitney Point	3V0 Installation	\$896,521	3.46	0%	
Windsor	3V0 Installation	\$737,509	4.13	0%	
Woodruff Pond	3V0 Installation	\$717,201	9.98	0%	
Wright Ave	3V0 Installation	\$402,710	4.90	34%	18 months

*Material lead time may impact this timeline

**Current Qualifying Upgrade Disclosure queue as of March 19, 2024