

NYSEG QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Afton	Substation Transformer	\$4,214,044	17.25	11%	3-5 years
Apalachin Tap	3V0 Installation	\$455,244	22.5	25%	18 months
Atlanta	Substation Transformer	\$376,410	18.3	27%	3-5 years
Auburn	3V0 Installation	\$661,915	5.169	0%	
Auburn	Distribution Line Upgrade	\$1,972,607	9.8	0%	
Axtell Rd	3V0 Installation	\$721,933	27.22	37%	18 months
Bankert Rd	3V0 Installation	\$631,533	10.3	0%	
Bankert Rd	Distribution Line Upgrade	\$621,000	4.28	0%	
Bankert Rd	Substation Transformer	\$3,864,106	6.381	0%	
Bennett	Distribution Line Upgrade	\$2,423,106	9.8	0%	
Bennett	Substation Transformer	\$3,864,952	10.5	0%	
Bennington	3V0 Installation	\$692,192	2.064	0%	
Bevier Street	3V0 Installation	\$610,778	4.59	0%	
Blodgett Rd Tap	Distribution Line Upgrade	\$1,863,000	4.4	0%	
Brooktondale Tap	Distribution Line Upgrade	\$993,600	25.89	0%	
Brothertown	3V0 Installation	\$676,057	2.9	0%	
Cabot Mine	3V0 Installation	\$698,039	7.569	0%	
Cabot Mine	Distribution Line Upgrade	\$2,205,868	3.88	0%	
Campbell	3V0 Installation	\$559,790	10.5	0%	
Campbell	Substation Transformer	\$4,011,385	10.5	0%	
Candor	Distribution Line Upgrade	\$307,662	27.1	0%	
Cemetery Rd	3V0 Installation	\$594,698	7.56	30%	18 months
Chemung	3V0 Installation	\$723,308	11.97	0%	
Chemung	Distribution Line Upgrade	\$627,210	9.8	0%	
Chemung	Substation Transformer	\$4,241,981	11.97	0%	
Chestnut Ridge	3V0 Installation	\$448,646	10.5	48%	18 months
Chestnut Ridge	Distribution Line Upgrade	\$496,800	10.5	100%	12 months
Columbus	3V0 Installation	\$468,239	16.8	30%	18 months
Craryville	3V0 Installation	\$612,365	6.646	19%	18 months
Dannemora	3V0 Installation	\$702,474	5.7	0%	
Dannemora	Substation Transformer	\$3,625,220	5.7	0%	
Earlville	3V0 Installation	\$518,882	2.5	48%	18 months
Earlville	Substation Transformer	\$2,413,544	5.47	0%	
Edmeston	3V0 Installation	\$698,039	10.5	0%	
Edmeston	Substation Transformer	\$4,030,875	10.5	0%	
Emmons	3V0 Installation	\$661,558	3.64	27%	3-5 years
Flat St	Distribution Line Upgrade	\$1,863,000	8.74	0%	
Fosterdale	Substation Modification	\$434,244	1.446	0%	
Frog Valley	3V0 Installation	\$966,485	24	0%	
Frog Valley	Substation Transformer	\$4,590,221	24	0%	
Fuller Hollow	3V0 Installation	\$436,141	16.8	0%	
Gainesville	Distribution Line Upgrade	\$1,111,838	27.114	0%	
Goss Rd	3V0 Installation	\$705,865	5.63	0%	
Goss Rd	Distribution Line Upgrade	\$2,431,660	3.77	0%	
Goss Rd	Substation Transformer	\$3,762,945	5.63	0%	
Grand Gorge	3V0 Installation	\$1,274,292	8.3	0%	
Grand Gorge	Distribution Line Upgrade	\$1,578,535	9.8	0%	
Grand Gorge	Substation Modification	\$4,271,473	2.63	0%	
Hammond Lane	3V0 Installation	\$698,039	11.65	30%	18 months
Hampton Rd	Distribution Line Upgrade	\$421,038	1.49	0%	
Hickling	Substation Regulator	\$544,626	3.756	0%	
Hyatt Rd	Distribution Line Upgrade	\$9,645,903	27.11	0%	
Hyde	3V0 Installation	\$717,201	4.12	0%	
Interlaken	3V0 Installation	\$709,309	16.8	0%	
Interlaken	Substation Transformer	\$4,659,006	16.8	0%	
Kattleville	3V0 Installation	\$676,056	21.833	0%	
Keeseeville	Distribution Line Upgrade	\$254,280	2.12	0%	
Kiamesha	Distribution Line Upgrade	\$1,532,462	3.158	0%	
Langdon	Distribution Line Upgrade	\$384,009	3.68	0%	
Langdon	Substation Transformer	\$6,453,509	2.63	0%	
Legion Drive	Distribution Line Upgrade	\$1,862,032	9.8	0%	
Legion Drive	Substation Transformer	\$3,474,831	5.63	0%	
Limestone	3V0 Installation	\$676,680	4.079	0%	
Limestone	Distribution Line Upgrade	\$310,500	9800	0%	
Limestone	Substation Transformer	\$4,013,146	8.93	0%	
Lounsbury	3V0 Installation	\$658,079	19.35	0%	
Lounsbury	Distribution Line Upgrade	\$2,608,604	9.8	0%	
Lounsbury	Substation Transformer	\$4,995,680	19.35	0%	
Ludlowville	3V0 Installation	\$737,510	8.63	0%	
Ludlowville	Substation Transformer	\$4,652,967	8.63	0%	
Lyon Mtn	3V0 Installation	\$654,777	10.449	0%	
Macedon	Distribution Line Upgrade	\$621,000	6.005	0%	
Maplewood	3V0 Installation	\$681,365	3.723	0%	
Maplewood	Distribution Line Upgrade	\$839,616	5.993	0%	
Masons Corners	3V0 Installation	\$676,057	16.8	30%	18 months
Masons Corners	Distribution Line Upgrade	\$1,536,598	9.8	0%	
Masons Corners	Substation Transformer	\$4,425,672	5.625	0%	
Meyer	Distribution Line Upgrade	\$496,800	3.16	0%	
Montour Falls	Distribution Line Upgrade	\$7,650,720	27.11	0%	
Montour Falls	Substation Transformer	\$6,946,715	10.5	0%	
Moraine Rd	Distribution Line Upgrade	\$347,760	2.241	100%	18 months
Moravia	3V0 Installation	\$384,856	4.2	86%	18 months
Morrisville	3V0 Installation	\$580,722	7.875	0%	
Morrisville	Distribution Line Upgrade	\$1,261,662	7.875	0%	
Morrisville	Substation Transformer	\$3,267,093	7.875	0%	
Naples	Distribution Line Upgrade	\$794,880	22.35	100%	18 months
Naples	Substation Regulator	\$535,902	15.14	26%	3-5 years
Northside	3V0 Installation	\$574,593	10.28	0%	
Northside	Distribution Line Upgrade	\$403,650	27.1	100%	18 months
Oakdale	Distribution Line Upgrade	\$1,242,000	27.11	0%	
Old Falls	Distribution Line Upgrade	\$2,984,685	9.8	0%	
Palmiter Rd	3V0 Installation	\$676,057	11.2	0%	
Palmiter Rd	Distribution Line Upgrade	\$1,304,510	9.8	0%	
Palmiter Rd	Substation Transformer	\$4,995,680	11.2	0%	

NYSEG QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Peru	3V0 Installation	\$717,201	4.64	0%	
Peruville Tap	Distribution Line Upgrade	\$621,000	25.12	0%	
Philo Road	3V0 Installation	\$549,933	16.8	25%	18 months
Pierce Ave	Distribution Line Upgrade	\$353,098	9.24	89%	12 months
Port Byron	3V0 Installation	\$610,778	10.5	0%	
Port Byron	Substation Transformer	\$4,366,875	10.5	0%	
Ridge Rd	3V0 Installation	\$658,026	27.75	0%	
Ridge Rd	Distribution Line Upgrade	\$2,527,470	9.8	0%	
Ridge Rd	Substation Transformer	\$5,109,439	21.67	0%	
Roscoe	3V0 Installation	\$656,442	5.19	0%	
Roscoe	Distribution Line Upgrade	\$564,494	3.89	0%	
Salem Tap	Distribution Line Upgrade	\$1,242,000	25.46	0%	
Seneca Falls	3V0 Installation	\$372,429	16.8	30%	18 months
Seneca Ordanance	3V0 Installation	\$467,957	3.75	96%	18 months
Silver Creek	Distribution Line Upgrade	\$738,990	TBD	100%	12 months
Sleight Rd	3V0 Installation	\$676,056	37.45	0%	
South Addison	Substation Transformer	\$4,035,524	6.75	0%	
South Junction	3V0 Installation	\$444,109	10.5	75%	18 months
South Lansing Tap	Distribution Line Upgrade	\$353,340	27.1	0%	
South Owego	Distribution Line Upgrade	\$458,807	27.11	0%	
South Owego	Substation Transformer	\$4,625,107	27.11	0%	
South Park	3V0 Installation	\$584,322	16.45	23%	18 months
Spencer Tap	Distribution Line Upgrade	\$856,347	3.77	0%	
Springfield Center	Distribution Line Upgrade	\$1,173,627	9.75	0%	
Springfield Center	Substation Transformer	\$4,319,915	7.07	0%	
Stanton Ave	3V0 Installation	\$701,175	7	43%	18 months
Stryker Ave	3V0 Installation	\$656,691	10.5	0%	
Stryker Ave	Substation Transformer	\$4,956,317	15.37	0%	
Ten Mile River	3V0 Installation	\$403,896	16.8	30%	18 months
Tilly Foster	3V0 Installation	\$438,558	27.975	25%	18 months
Tom Miller Rd	3V0 Installation	\$578,354	14.7	0%	
Van Buren St	3V0 Installation	\$391,470	10.5	85%	18 months
Van Buren St	Distribution Line Upgrade	\$7,452,000	4.536	0%	
Vincent Corners	3V0 Installation	\$624,247	9	0%	
Vincent Corners	Substation Transformer	\$3,703,540	9	0%	
Walden	3V0 Installation	\$600,019	11.18	0%	
Walden	Distribution Line Upgrade	\$3,210,570	20.84	0%	
Walden	Substation Transformer	\$3,873,959	11.18	0%	
Wales Center	3V0 Installation	\$672,180	1.372	0%	
Warners	Distribution Line Upgrade	\$13,662,000	27.11	0%	
Warsaw	3V0 Installation	\$327,038	4.99	0%	
Warsaw	Distribution Line Upgrade	\$621,000	TBD	0%	
Warsaw	Substation Transformer	\$2,298,900	8.669	0%	
Wayland	Distribution Line Upgrade	\$310,500	3.77	0%	
Weedsport	3V0 Installation	\$681,365	3.4	0%	
Weedsport	Distribution Line Upgrade	\$1,242,000	2.3	0%	
West Hill	3V0 Installation	\$628,854	6.901	72%	18 months
West Varysburg	3V0 Installation	\$681,365	4.098	0%	
West Varysburg	Distribution Line Upgrade	\$1,664,280	7.56	0%	
West Winfield	3V0 Installation	\$717,201	5.67	0%	
West Winfield	Substation Transformer	\$3,434,495	5.67	0%	
Whiskey Creek	3V0 Installation	\$658,242	7.35	0%	
Whiskey Creek	Substation Transformer	\$3,703,540	7.35	0%	
Woodruff Pond	3V0 Installation	\$717,201	9.975	0%	
Wright Ave	Substation Modification	\$402,710	14.8	34%	3-5 years
Wyantskill	Distribution Line Upgrade	\$373,842	1.31	0%	

\*Material lead time may impact this timeline

\*\*Current Qualifying Upgrade Disclosure queue as of November 24, 2023