		NYSEG QUALIFYING UPGRADE	DISCLOSURE		
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Amawalk	3V0 Installation	\$756,641	27.90	25%	18 months
Apalachin Tap	Distribution Line Upgrade	\$591,238	27.10	0%	
Arkville	3V0 Installation	\$658,051	6.60	75%	18 months
Atlanta	Substation Regulator	\$376,410	18.30	27%	3-5 years
Axtell Rd Axtell Rd	3V0 Installation	\$617,654	27.22	37%	18 months
	Substation Transformer	\$11,357,772	9.20 9.80	0% 100%	10 months
Bailey Hill Tap Bainbridge	Distribution Line Upgrade Substation Transformer	\$356,234 \$8,780,214	24.20	75%	18 months 3-5 years
Banker Road	3V0 Installation	\$6,780,214	16.80	75% 48%	18 months
Banker Road	3V0 Installation	\$853,070	5.20	0%	10 1110111113
Banker Road	Distribution Line Upgrade	\$2,011,784	9.80	0%	
Banker Road	Substation Regulator	\$1,731,212	3.70	0%	
Banker Road	Substation Transformer	\$10,427,022	28.00	0%	
Bankert Rd	3V0 Installation	\$582,866	5.21	81%	18 months
Bankert Rd	Distribution Line Upgrade	\$621,000	3.16	81%	18 months
Benjamin Hill	3V0 Installation	\$865,537	3.30	0%	
Bennett	Distribution Line Upgrade	\$621,000	9.80	100%	18 months
Bennett	Distribution Line Upgrade	\$621,621	26.27	0%	
Bennett	Substation Regulator	\$428,508	5.67	72%	18 months
Broad Street	3V0 Installation	\$865,537	4.90	0%	
Broad Street	Distribution Line Upgrade	\$1,007,695	7.60	0%	
Brooktondale Tap	Distribution Line Upgrade	\$1,676,700	25.89	100%	18 months
Brooktondale Tap	Substation Regulator	\$1,490,162	15.16	94%	18 months
Cabot Mine	3V0 Installation	\$865,537	3.60	0%	
Campbell	Substation Transformer	\$7,212,218	10.50	0%	
Cayuga	3V0 Installation	\$865,537	3.60	0% 0%	
Cayuta Cayuga	3V0 Installation Substation Regulator	\$865,537 \$2,087,165	1.40 2.10	0% 0%	
Cayuga Cemetery Road	3V0 Installation	\$865,537	6.00	0%	
Chateaugay	Distribution Line Upgrade	\$1,267,461	9.20	0%	
Chateaugay	Substation Transformer	\$14,636,128	27.90	0%	
Chemung	Distribution Line Upgrade	\$750,789	9.80	0%	
Chemung	Substation Transformer	\$20,356,830	20.10	0%	
Chemung	3V0 Installation	\$865,537	4.10	0%	
Chenango Bridge	Substation Regulator	\$1,620,638	3.60	0%	
Chestnut Ridge	3V0 Installation	\$448,646	10.50	48%	18 months
Chestnut Ridge	Distribution Line Upgrade	\$496,800	10.50	100%	18 months
Columbus	3V0 Installation	\$468,239	16.80	58%	18 months
Conklin	3V0 Installation	\$865,537	3.60	0%	
Conklin	Source Regulator	\$1,620,638	2.10	0%	
Delhi	Distribution Line Upgrade	\$310,027	9.80	100%	18 months
Dover Plains	3V0 Installation	\$514,074	6.30	56%	18 months
Dryden Tap	Distribution Line Upgrade	\$741,101	1.49	0%	
Earlville	3V0 Installation ³	\$651,184	10.50	38%	18 months
Ellington	3V0 Installation	\$661,558	4.50	0%	
Emmons	3V0 Installation	\$661,558	3.64	27%	18 months
Fallbrook	Distribution Line Upgrade	\$4,909,015	8.50	0%	
Flat Street	Distribution Line Upgrade	\$3,105,000	8.70	0%	18 months
Flat Street	Distribution Line Upgrade	\$3,105,000	8.70	0%	
Fosterdale	Substation Regulator	\$434,244	1.45	25%	18 months
Gainesville	Distribution Line Upgrade	\$1,111,838	27.11	25%	
Granville	Substation Regulator	\$1,589,396	7.30	0%	
Granville- Salem Tap	Distribution Line Upgrade	\$527,783	25.60	0%	10
Hammond Lane	3VO Installation	\$428,401	11.65	30%	18 months
Hammond Lane	3V0 Installation	\$865,537	8.10 9.80	0% 25%	
Hammond Lane Hammondsport	Distribution Line Upgrade Distribution Line Upgrade	\$2,878,965 \$2,890,134	9.80 3.20	25% 0%	
Hammondsport	3V0 Installation	\$865,538	3.40	0%	
Hampton Road	3V0 Installation	\$865,537	3.70	100%	18 months
Harford	Distribution Line Upgrade	\$2,412,585	TBD	0%	20011013
Hickling	Substation Regulator	\$1,282,649	7.50	58%	18 months
Hillcrest	Distribution Line Upgrade	\$417,312	5.90	0%	
Hillcrest	3V0 Installation	\$865,537	12.00	0%	
Hillcrest Rd.	3V0 Installation	\$565,091	6.60	0%	
Hoadley Hill Tap	Distribution Line Upgrade	\$794,880	6.20	0%	
Hyatt Rd	Distribution Line Upgrade	\$496,800	9.80	100%	18 months
Hyde Road	Distribution Line Upgrade	\$282,555	9.80	0%	
Hyde Road	3V0 Installation	\$865,538	4.05	0%	
Kattelville	3V0 Installation	\$861,293	28.80	44%	18 months
Kattelville	3V0 Installation	\$967,030	56.00	0%	
Lakeshore	Distribution Line Upgrade	\$1,925,100	4.90	0%	
Lakeshore	Distribution Line Upgrade	\$4,527,720	9.80	0%	
Langdon	Distribution Line Upgrade	\$384,009	3.68	100%	18 months
Langdon	Distribution Line Upgrade	\$1,106,001	27.10	0%	
Langdon	3V0 Installation	\$865,537	6.10	0%	40
Legion Drive	Substation Regulator	\$595,097	8.00	25%	18 months
Lehigh St	3V0 Installation	\$1,031,117	4.70	0%	
Lehigh St	Distribution Line Upgrade	\$1,895,316	9.80	0%	
Lehigh St	Line Regulator	\$4,548,497	5.60	0%	
Lehigh St	Substation Transformer	\$9,342,597	6.30	0%	
Lounsberry	3V0 Installation	\$658,079	19.35	0%	
Limestone	Substation Transformer	\$9,194,706	2.60	0%	
Limestone	3V0 Installation	\$865,537	4.00	0%	
Limestone	Substation Regulator	\$1,620,638	3.70	0%	
Lounchores	Distribution Line Unesade	¢2 600 604			
Lounsberry Lounsberry	Distribution Line Upgrade Substation Transformer	\$2,608,604 \$4,995,680 ⁺	9.80 19.35	0% 0%	

		NYSEG QUALIFYING UPGRADE	DISCLOSURE		
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Lyon Mountain	Distribution Line Upgrade	\$565,110	23.10	0%	
Lyon Mountain	Substation Transformer	\$13,822,232	6.30	0%	
Macedon	Distribution Line Upgrade	\$621,000	6.01	100%	18 months
Madison Ave	3V0 Installation	\$865,837	8.10	0%	
Madison Ave	Distribution Line Upgrade	\$5,468,488	9.80	0%	
Madison Ave	Substation Regulator	\$1,620,638	5.10	0%	
Masons Corners	3V0 Installation ¹	\$865,537	14.60	65%	18 months
Montour Falls	Distribution Line Upgrade	\$7,650,720	27.11	0%	
Moraine Rd	Distribution Line Upgrade	\$272,060	8.70	25%	
Morrisville	Distribution Line Upgrade	\$621,621	9.80	0%	40
Moravia	3V0 Installation	\$384,856	4.20	86%	18 months
Montour Falls	Substation Transformer	\$6,946,715*	10.50	0%	40
Naples	Distribution Line Upgrade	\$794,880	22.35	100%	18 months
Naples New Berlin	Substation Regulator 3V0 Installation	\$535,902 \$865,537	15.14 4.10	26% 0%	3-5 years
New Berlin	Distribution Line Upgrade	\$541,762	5.60	0%	
New Berlin	Line Regulator	\$1,620,638	2.10	0%	
New Corning	3V0 Installation	\$865,537	11.70	39%	18 months
New Corning	Distribution Line Upgrade	\$530,744	7.60	25%	20 1110111115
North Broadway	3V0 Installation	\$767,024	15.70	25%	18 months
Northside	Distribution Line Upgrade	\$403,650	27.10	100%	18 months
Oaks Corners	3V0 Installation	\$658,243	3.65	96%	18 months
Ouaquaga West	Line Regulator	\$296,935	4.70	0%	
Palmiter Rd	3V0 Installation ²	\$676,057	11.20	18%	Ī
Palmiter Rd	Distribution Line Upgrade	\$268,272	8.90	100%	18 months
Peru	Distribution Line Upgrade	\$1,041,417	6.60	0%	
Peruville Tap	Distribution Line Upgrade	\$621,000	25.12	100%	18 months
Peruville Tap	Distribution Line Upgrade	\$516,672	2.80	0%	
Philo Road	3V0 Installation	\$549,933	16.80	28%	18 months
Philo Road	Distribution Line Upgrade	\$650,000	8.50	0%	
Pierce Ave	Distribution Line Upgrade	\$353,098	9.24	89%	18 months
Richfield Springs	Substation Regulator	\$1,382,624	2.10	0%	
Ridge Road	Substation Transformer	\$8,559,050	8.90	0%	
Ridge Road	Distribution Line Upgrade	\$2,161,080	9.80	0%	
Riverside	Distribution Line Upgrade	\$1,953,666	9.80	0%	
Rock Hill	Distribution Line Upgrade	\$315,195	9.80	100%	18 months
Roscoe	3V0 Installtion	\$865,537	5.10	0%	
Roscoe	Substation Regulator	\$1,412,357	1.80	0%	10 months
Seneca Falls Seneca Falls	3V0 Installation	\$372,479	6.38 7.58	30% 30%	18 months 18 months
Seneca Ordanance	Distribution Line Upgrade 3V0 Installation	\$1,242,000 \$585,938	7.58 5.60	96%	18 months
Seneca Ordanance	Substation Regulator	\$1,620,638	18.90	0%	10 1110111113
Silver Creek	Distribution Line Upgrade	\$738,990	TBD	100%	18 months
Silver Springs	Substation Regulator	\$1,620,637	2.10	0%	10 111011113
Sleight Rd	3V0 Installation	\$676,056	37.45	6%	
South Addison	Distribution Line Upgrade	\$1,235,169	9.80	0%	
South Cooperstown	Distribution Line Upgrade	\$343,004	2.00	0%	
South Junction	3V0 Installation	\$444,109	10.50	75%	18 months
South Lansing Tap	Distribution Line Upgrade	\$353,340	27.10	100%	18 months
South Owego	Substation Regulator	\$1,299,312	4.00	0%	
South Park	3V0 Installation	\$584,322	16.45	23%	
Springfield Center	3V0 Installation	\$665,429	6.30	0%	
Stanton Ave	3V0 Installation	\$701,175	7.00	43%	18 months
Stanton Ave	3V0 Installation	\$884,582	3.70	0%	
Stolle Road	Distribution Line Upgrade	\$869,400	23.60	100%	18 months
Sylvan Lake	3V0 Installation	\$865,537	7.90	0%	
Sylvan Lake	Distribution Line Upgrade	\$1,531,829	10.30	0%	10 mantha
Ten Mile River Tilly Foster	3V0 Installation 3V0 Installation	\$403,896 \$438,558	16.80 27.98	30% 25%	18 months 18 months
Tom Miller Rd	3V0 Installation 3V0 Installation	\$438,558 \$865,538	27.98 14.70	25% 0%	10 1110111112
Transit	Substation Regulator	\$1,137,666	9.40	0%	
Van Buren St	3V0 Installation	\$865,537	16.40	65%	18 months
Van Buren St	Distribution Line Upgrade	\$1,490,400	5.50	25%	
Van Buren St	3V0 Installation	\$865,537	16.40	0%	Ī
Van Buren St	Distribution Line Upgrade	\$1,463,034	9.80	0%	
Vestal	3V0 Installation	\$700,521	7.60	0%	
Voak	Substation Regulator	\$1,326,439	6.40	0%	
Walden	Substation Transformer w/3V0	\$16,371,428	11.20	0%	Ī
Walden	Distribution Line Upgrade	\$777,182	3.60	0%	Ī
Warsaw	3V0 Installation	\$327,038	4.99	42%	18 months
Warsaw	3V0 Installation	\$865,538 ⁵	7.90	0%	Ī
Warsaw	Distribution Line Upgrade	\$521,640	3.90	0%	
Warsaw	Regulator	\$1,620,638	3.70	0%	
Webbs Crossing	3V0 Installation	\$865,537	5.20	0%	1
Wehrle	3V0 Installation	\$865,537	5.40	86%	18 months
Wehrle	Distribution Line Upgrade	\$385,020	3.80	0%	1
West Chazy	3V0 Installation	\$760,897	3.00	0%	1
West Chazy	Substation Regulator	\$1,440,955	1.40	0%	1
West Hill	3V0 Installation	\$628,854	6.90	72%	18 months
Wehrle	3V0 Installation	\$865,537	4.70	0%	
Wehrle	Distribution Line Upgrade	\$385,020	3.80	0%	
Willet	Distribution Line Upgrade	\$1,273,050	27.10	0%	ĺ
Windsor	3V0 Installation	\$737,509	4.13	0%	
Woodruff Pond	3V0 Installation	\$865,537	9.90	0%	Ī
Woodruff Pond	Distribution Line Upgrade	\$4,125,303	9.80	0%	10
Wright Ave	3V0 Installation	\$402,710	4.90	34%	18 months

NYSEG QUALIFYING UPGRADE DISCLOSURE								
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*			
Yulan	3V0	\$865,537	5.3	0				

^{*}Material lead time may impact this timeline
**Current Qualifying Upgrade Disclosure queue as of November 19, 2025

¹ Masons Corners 3V0 - 25% pymt made on \$658,026 upgrade

²Palmiter Rd 3V0 - 30% pymt made on \$409,542 upgrade

 $^{^3}$ Earlville 3V0 - 48% pymt made on \$518,882 upgrade

⁴Banker Rd 3V0 - 48% pymt made on \$631,353 upgrade